Certificate

Passive House Suitable Component

For cool temperate climates, valid until 31. December 2026

Passivhaus Institut
Dr. Wolfgang Feist
64283 Darmstadt
GERMANY

Category: **Compact Heat Pump System**

Manufacturer: **Nilan A/S**
8722 Hedensted, DENMARK

Product name: **Compact P (92 m³/h)**

This certificate was awarded based on the following criteria (limit values*):

Thermal Comfort:	$\theta_{supply\ air} \geq 16{,}5°C$
Heat Recovery of ventilation system:	$\eta_{WRG,eff} \geq 75\%$
Electric efficiency ventilation system:	$P_{el} \leq 0{,}45$ Wh/m³
Air tightness (internal/external):	$V_{Leakage} \leq 3\%$
Total Primary Energy Demand (**):	$PE_{total} \leq 55$ kWh/(m²a)
Control and calibration (*)	
Air pollution filters (*)	
Anti freezing strategy (*)	
Noise emission and reduction (*)	

Measured values to be used in PHPP (set point 92 m³/h)
useful air flow rates 52 to 120 m³/h

Heating

		Test point 1	Test point 3	Test point 3	Test point 4	
Outside Air Temperature	T_{amb}	**-7.0**	**2.1**	**7.1**		°C
Thermal Output Heating Heat Pump	$P_{WP,Heiz}$	**0.49**	**0.62**	**0.67**		kW
COP number Heating Heat Pump	COP_{Heiz}	**2.43**	**2.55**	**2.78**		-
Maximum available supply air temperature with Heat Pump only(*)		**33.6**				°C

Hot water

		Test point 1	Test point 3	Test point 3	Test point 4	
Outside Air Temperature	T_{amb}	**-6.9**	**1.9**	**7.2**	**20.2**	°C
Thermal Output Heat Pump for heating up storage tank.	P_{DHW} heating up	**0.51**	**0.72**	**0.89**	**1.02**	kW
Thermal Output Heat Pump for reheating storage tank	P_{DHW} reheating	**0.54**	**0.71**	**0.83**	**0.94**	kW
COP Heat Pump for heating up storage tank	$COP_{DHW,}$ heating up	**2.11**	**2.60**	**3.08**	**3.38**	-
COP Heat Pump for reheating storage tank	COP_{DHW} reheating	**1.94**	**2.50**	**2.80**	**3.05**	-
Averge storage tank temperature		**50.5**				°C
Specific storage heat losses		**1.63**				W/K
Exhaust air addition (if applicable)						m³/h

Heat Recovery
$\eta_{WRG,eff}$ = 77%

Electric efficiency
0.43 Wh/m³

Air tightness
$V_{leak,\ internal}$ = 1.0%
$V_{leak,\ external}$ = 1.1%

Frost protection
down to -7 °C

Total Primary Energy Demand (**)
54.1 kWh/(m²a)

(*) detailed description of criteria and key values see attachment.
(**) for heating, domestic hot water (DHW), ventilation, auxiliary electricity in the reference building, explanation see attachment.

CERTIFIED COMPONENT
Passive House Institute

www.passivehouse.com

0390ch03

Certificate

Passive House Suitable Component

For cool temperate climates, valid until 31. December 2025

Passivhaus Institut
Dr. Wolfgang Feist
64283 Darmstadt
GERMANY

Category: **Compact Heat Pump System**

Manufacturer: **Nilan A/S**
8722 Hedensted, DENMARK

Product name: **Compact P (172 m³/h)**

This certificate was awarded based on the following criteria (limit values*):

Thermal Comfort:	$\theta_{supply\ air} \geq 16{,}5°C$
Heat Recovery of ventilation system:	$\eta_{WRG,eff} \geq 75\%$
Electric efficiency ventilation system:	$P_{el} \leq 0{,}45$ Wh/m³
Air tightness (internal/external):	$V_{Leakage} \leq 3\%$
Total Primary Energy Demand (**):	$PE_{total} \leq 55$ kWh/(m²a)
Control and calibration (*)	
Air pollution filters (*)	
Anti freezing strategy (*)	
Noise emission and reduction (*)	

Measured values to be used in PHPP (set point 172 m³/h)
useful air flow rates 120 to 205 m³/h

Heating

		Test point 1	Test point 3	Test point 3	Test point 4	
Outside Air Temperature	T_{amb}	**-3.7 °C**	**2.0 °C**	**6.9 °C**		°C
Thermal Output Heating Heat Pump	$P_{heating}$	**0.61**	**0.78**	**0.92**		kW
COP number Heating Heat Pump	$COP_{Heating}$	**2.65**	**3.18**	**3.58**		-
Maximum available supply air temperature with Heat Pump only(*)		**28.6**				°C

Hot water

		Test point 1	Test point 3	Test point 3	Test point 4	
Outside Air Temperature	T_{amb}	**-4.0 °C**	**2.0 °C**	**7.0 °C**	**20.2 °C**	°C
Thermal Output Heat Pump for heating up storage tank.	P_{DHW} heating up	**0.60**	**0.83**	**0.99**	**1.14**	kW
Thermal Output Heat Pump for reheating storage tank	P_{DHW} reheating	**0.53**	**0.82**	**0.95**	**1.05**	kW
COP Heat Pump for heating up storage tank	COP_{DHW} heating up	**2.13**	**2.87**	**3.31**	**3.68**	-
COP Heat Pump for reheating storage tank	COP_{DHW} reheating	**1.81**	**2.72**	**3.05**	**3.28**	-
Averge storage tank temperature		**50.5**				°C
Specific storage heat losses		**1.63**				W/K
Exhaust air addition (if applicable)						m³/h

Heat Recovery
$\eta_{WRG,eff}$ = 80%

Electric efficiency
0.40 Wh/m³

Air tightness
$V_{leak,\ internal}$ = 1.0%
$V_{leak,\ external}$ = 1.1%

Frost protection
down to -4 °C

Total Primary Energy Demand (**)
51.4 kWh/(m²a)

(*) detailed description of criteria and key values see attachment.
(**) for heating, domestic hot water (DHW), ventilation, auxiliary electricity in the reference building, explanation see attachment.

CERTIFIED COMPONENT
Passive House Institute

www.passivehouse.com

0391ch03